

### SCHEDULE 3

#### EMISSIONS TO AIR: REPORT OF CONTINUOUS MONITORING RESULTS. A8

Release Summary for month of November 2008

Permit Number BL1096

Castle Cement Ltd, Padeswood Works

<b>Form M/A5 – Air Continuous Monitoring</b>					
<b>Substance</b>	<b>Average concentration during month, mg/m<sup>3</sup></b>	<b>Maximum <sup>1</sup>daily mean concentration recorded during month, mg/m<sup>3</sup></b>	<b>Maximum <sup>1</sup>half hourly mean concentration recorded during month, mg/m<sup>3</sup></b>	<b>Number of <sup>1</sup>half hours / days in the month in which limit in column 2 of Tables 6.1.3 exceeded*</b>	<b>Kiln operating time during month that monitor and recording equipment available (hrs)</b>
Particulates	3.88	6.31	9.59	0 half hours 0 days	542.5 / 542.5
Oxides of Nitrogen as NO <sub>2</sub>	424	504	968	0 half hours 0 days	542.5 / 542.5
SO <sub>2</sub>	44.5	100	290	0 half hours 0 days	542.5 / 542.5
Volatile Organic Compounds as Total Organic Carbon	14.9	18.5	30.5	0 half hours 0 days	542.5 / 542.5
Carbon Monoxide	406	531	1050	0 half hours 0 days	542.5 / 542.5
Hydrogen Chloride	1.07	3.39	9.49	0 half hours 0 days	542.5 / 542.5

<sup>1</sup> As appropriate

\* This excludes periods during instrument calibration

PLANT OPERATING TIME / SYSTEM OPERATING TIME

**Signed on behalf of the Operator**

**Dated 08/12/2008**

**Form M/A5**